













































PIPEWORK FITTINGS, VALVES & EQUIPMENT

	ISOLATING VALVE
	DOUBLE REGULATING VALVE
	BALANCING VALVE (COMMISSIONING SET)
	2-PORT MOTORISED VALVE
	3-PORT MOTORISED VALVE
	DRAIN COCK
	SAFETY - PRESSURE RELIEF VALVE
	DIFFERENTIAL PRESSURE CONTROL VALVE
	THERMOSTATIC RADIATOR VALVE
	LOCKSHEILD VALVE
	NON RETURN VALVE
	STRAINER
	PUMP
	MANUAL AIR VENT
	AUTOMATIC AIR VENT
	AIR BOTTLE WITH MANUAL VENT
	FLEXIBLE CONNECTION
	FLANGED CONNECTION
	UNION CONNECTION
	WATER METER
	GAS METER
	FLOW METER

DUCTWORK FITTINGS & EQUIPMENT

	RECTANGULAR DUCTWORK
	CIRCULAR DUCTWORK
	SUPPLY AIR DUCTWORK (WITH FLOW DIRECTION)
	RETURN/EXHAUST AIR DUCTWORK (WITH AIR FLOW DIRECTION)
	FLEXIBLE DUCTWORK
	FIRE RATED DUCTWORK
	VERTICAL DUCTWORK VIEWED FROM ABOVE
	VERTICAL DUCTWORK VIEWED FROM BELOW
	CEILING MOUNTED SUPPLY DIFFUSER
	CEILING MOUNTED EXTRACT GRILLE
	CEILING MOUNTED LINEAR SLOT DIFFUSER
	SIDEWALL SUPPLY DIFFUSER
	SIDEWALL EXTRACT GRILLE
	AIR TRANSFER GRILLE
	EXTERNAL LOUVRE
	ATTENUATOR
	CROSS-TALK ATTENUATOR
	VOLUME CONTROL DAMPER
	FIRE DAMPER
	PRESSURE RELIEF DAMPER
	NON-RETURN DAMPER



PLANT REFERENCING NOTATION



AC	AIR CONDITIONING UNIT	HX	HEAT EXCHANGER
AHU	AIR HANDLING UNIT	L	LOUVRE
AT	ATTENUATOR	MWC	MAGNETIC WATER CONDITIONER
AV	DISC VALVE	OT	OIL STORAGE TANK
B	BOILER	P	PUMP
BT	BOOSTER SET	PU	PRESSURISATION UNIT
CB	CHILLED BEAM	R	RADIATOR
CH	CHILLER	RP	RADIANT PANEL
CHP	COMBINED HEAT & POWER UNIT	SD	SUPPLY AIR DIFFUSER
CT	COOLING TOWER	SG	SUPPLY GRILLE
CU	CONDENSING UNIT	SP	SUMP PUMP
EF	EXTRACT FAN	TC	TRENCH CONVECTOR
EG	EXTRACT GRILLE	UH	UNIT HEATER
ER	ELECTRIC RADIATOR	UV	ULTRA VIOLET WATER TREATMENT
FCU	FAN COIL UNIT	WH	WATER HEATER
FCO	FAN CONVECTOR	WS	WATER SOFTENER
HB	HEATER BATTERY	WT	WATER STORAGE TANK
HU	HUMIDIFIER		
HW	HOT WATER CALORIFER		

PIPE & DUCT SIZING NOTATION

PIPE SIZE (mm dia)	DUCT SIZE (mm dia / w x h)
FLOW RATE (l/h)	FLOW RATE (m³/h)

 <p><b>DOMAA</b> projektovanje, konsalting, inženjering Beograd, Kneza Miloša 82 tel. 011 361 4634, 2656 251 www.domaa.rs e-mail: office@domaa.rs</p>  <p><b>AERPROJEKT</b> consulting engineers društvo za projektovanje, konsalting i inženjering Dubrovačka 14, Beograd; tel:011/2463-344; e-mail: info@aerprojekt.com</p>	investitor <b>DELEGACIJA EU PRI REPUBLICI SRBIJI</b> ul.Vladimira Popovića br.40, GTC Avenija, blok 19a, Novi Beograd		
	objekat i mesto gradnje	<b>POSLOVNI PROSTOR</b> ul.Kralja Milana br.7, Beograd	
	deo projekta	<b>GLAVNI PROJEKAT REKONSTRUKCIJE U OKVIRU GABARITA I VOLUMENA POSTOJEĆEG POSLOVNOG PROSTORA U UL. KRALJA MILANA br. 7 U BEOGRADU</b>	
	crtež	<b>MECHANICAL SERVICES SYMBOLS AND NOTATIONS</b>	
	projekat <b>G.P.</b>	razmera <b>1:75</b>	datum <b>November 2014</b> br crteža <b>M 01</b>